



LEGEND:
 20FL - 20 FT MINIMUM FIRE LANE
 30FL - 30 FT MINIMUM FIRE LANE
 ALL GATES WILL BE INSTALLED WITH A KNOX BOX FOR RAPID ENTRY


PRIMARY FIRE ACCESS
 SNOWDOWN E.V.A.:
 WIDTH: 20 FT
 # OF TURNOUTS: PER CODE
 TYPE OF MATERIAL: ROCK TO SUPPORT FIRE TRUCK

PROPOSED PUMP HOUSE, PEERLESS TYPE PUMPING SYSTEM NFPA 24 COMPLIANT PRESSURIZED SYSTEM. NO STORAGE TANK REQUIRED ON CALIFORNIA EXHIBIT.

SECONDARY FIRE ACCESS
 PROPOSED 14' PAVED MAINTENANCE ROAD. NOT A COMPLIANT FIRE ACCESS ROAD. (NO TURNOUTS)

ALIQUOT
 PLANNERS
 CIVIL ENGINEERS
 SURVEYORS
 1390 SOUTH MAIN STREET
 SUITE 310
 WALNUT CREEK, CA, 94596
 (925) 476-2300
 FAX (925) 476-2350

NO.	BY	DATE	REVISIONS



FIRE SERVICE EXHIBIT
 KNOWLAND PARK - OAKLAND ZOO
 ALAMEDA COUNTY CALIFORNIA

RECEIVED
 JAN 27 2010
 City of Oakland
 Planning & Zoning Division

JOB NO 208022	SCALE 1"=120'	DATE 1/7/2010	DESIGN	DRAWN MC	APPROVED
DRAWING NUMBER					